

BALOCHISTAN ENERGY COMPANY LIMITED

DEVELOPMENT OF LPG TESTING LABORATORY AT TAFTAN

SPECIFICATION FOR VALVE INSTALLATION



Office Address:

Balochistan Energy Company Limited
67-A, Main Jinnah Town Quetta,
Balochistan, Pakistan

Phone: 9281-2863711, 2863712

E-mail: cfo@becl.com.pk

shayan.ali.siddiqui@gmail.com

Web: www.becl.com.pk



SPECIFICATION FOR VALVE INSTALLATION

VALVE INSTALLATION

- 1) This specifications covers the minimum requirements for the installation of Valves for the LPG Testing Laboratory at Taftan.
- 2) The valves shall be kept in closed position at all times before installation for protection of the valve seats.
- 3) During welding operations of butt-welded end valves, the valves shall be opened and their seats properly protected.
- 4) Valves' flange or screwed connections shall be protected by proper means before erection.
- 5) During installation undue stresses shall be avoided by proper alignment of piping section, so that the free moving of gate or ball between the seats shall be preserved.
- 6) During installation valve flanges shall be tightened properly with appropriate torque applied.